



**IRCCOS** S.c.a r.l.

*Istituto di Ricerca e certificazione per le Costruzioni Sostenibili*

Test Laboratory Notified in accordance with Directive 89/106/CEE No. 1994

## TEST REPORT

*Number:*

**1994-CPD-RP0906**

*Issuing date:*

**2013-01-30**

*Applicant:*

**Etem SA**

**Iroon Polytechniou str, 1  
1908 – Magoula, Attiki (Greece)**

*Tested product:*

**Double wing balcony door of E38 series**

**Trade name: "E38\_DOUBLE WING BALCONY DOOR"**

*(cf. description)*

*Executed tests:*

**Air permeability**

**Watertightness**

**Resistance to wind load**

*Normative References:*

**EN 14351-1:2006+A1:2010**

**EN 1026:2000**

**EN 12207:1999**

**EN 1027:2000**


**EN 12208:1999**

**EN 12211:2000**

**EN 12210:1999**

*The report is done up of 27 pages, including any annex, and can be reproduced only integrally.*

- 9 Resume of classes assigned on the basis of the results of the tested sample of double wing balcony door of E38 series with trade name “E38\_DOUBLE WING BALCONY DOOR”, according to TR n° 1994-CPD-RP0906, issued on 2013-01-30 to ETEM SA.

Scheme of the tested sample	Test	Test standard	Classification standard	Obtained Class	Cf. § TR
 2310(H) x 1610(W) mm	Air permeability	EN 1026:2000	EN 12207:1999	class 4	§ 7.2.1
	Watertightness	EN 1027:2000	EN 12208:1999	class E900	§ 7.3.1
	Resistance to wind load	EN 12211:2000	EN 12210:1999	class C2	§ 7.4.5

## 10 Limitations

This Test Report does not represent either an evaluation the suitability of use or a certificate of product conformity. The results obtained refer exclusively to the samples tested.

### Technical Operators

*Dario Badioli*

*Elisa Farioli*

*Dario Badioli*  
*Elisa Farioli*

### The chairman

*for Dott. Italo Meroni*

*Katia Foti*

-----End of the Test Report No. 1994-CPD-RP0906-----