



**IRCCOS** S.c.a r.l.

*Istituto di Ricerca e certificazione per le Costruzioni Sostenibili*

Test Laboratory Notified in accordance with Regulation (EU) No 305/2011

## TEST REPORT

*Number:*

**1994-CPR-RP1298**

(Issued in replacement of the Test Report n. 1994-CPR-RP1176 of 01/07/2015)

*Issuing date:*

**3 February 2016**

*Applicant:*

**ETEM BULGARIA S.A**  
**119A, Ilenci Blvd, Sofia, 1220, Bulgaria**

*Tested product:*

**Single vent with fixed light**

**Trade name: "E38"**

*(cf. description)*

*Executed tests:*

**Air permeability**

**Watertightness**

**Resistance to wind load**

*Normative References:*

**EN 14351-1:2006+A1:2010**

**EN 1026:2000      EN 12207:1999**

**EN 1027:2000      EN 12208:1999**

**EN 12211:2000      EN 12210:1999**


*The report is done up of 25 pages, including any annex, and can be reproduced only integrally.*

*Sede legale Via Achille Grandi 71 - 21017 Samarate (VA) - Tel. 0331 594628 - [www.irccos.com](http://www.irccos.com)*

*Cap. Soc. € 111.526 I.V. - C.F. e P. Iva 05159630960 - Reg. Imprese Milano 05159630960 - R.E.A. 1799766*

*Società partecipata a maggioranza dal Consiglio Nazionale delle Ricerche*

9 Resume of classes assigned on the basis of the results of the tested sample of a double vent sliding door-standard version- with trade name “E38”, according to TR n° 1994-CPR-RP1298, issued on 03-02-2016 to ETEM BULGARIA S.A..

Scheme of the tested sample	Test	Test standard	Classification standard	Obtained Class	Cf. § TR
	Air permeability	EN 1026:2000	EN 12207:1999	class A	§ 7.2.1
	Watertightness	EN 1027:2000	EN 12208:1999	class E750	§ 7.3.1
	Resistance to wind load	EN 12211:2000	EN 12210:1999	class C3	§ 7.4.5

**10 Limitations**

This Test Report does not represent either an evaluation the suitability of use or a certificate of product conformity. The results obtained refer exclusively to the samples tested.

**Technical Operator**

*Katia Foti  
Matteo Mariotto*

*Katia Foti  
Matteo Mariotto*

**The Technical Director**

*Giovanni Cavanna*

*Giovanni Cavanna*

-----End of the Test Report No. 1994-CPR-RP1298-----